South Dakota Department of Health

DIVISION OF ADMINISTRATION

Public Health Laboratory

615 East Fourth Street
Pierre, South Dakota 57501-1700
605/773-3368 FAX: 605/773-6129
www.state.sd.us/doh/lab/index.htm

Date: 6/7/2006

Submitter copy to:

LAURENZ,ROB-106862
207 E MISSOURI AVE
PIERRE, SD 57501

Spec #: E06WB005648
Subm #:
Lab: ENV CHEMISTRY
Tel #: (605)773-3368

Source

LAURENZ,ROB

Date Rcvd: 6/5/2006
Time Rcvd: 0832
Date Coll: 6/1/2006
Time Coll: 1730
Spec Type: WATER
Coll Site: WELL
Coll By: BRAD BRISCOE

Date drilled: 11-12-05
Drilled by: TAYLOR
Pump inst by: WATER WELL WORKS
Telephone Numb* 9451427
Well Depth: 520 FT
Supply Type: PRIVATE
Sample Purpose: ROUTINE

Final Results

Sulfate	<10.0 mg/L	
Sodium	1.7 mg/L	
Conductivity	191 umho/cm	
Nitrate	<0.1 mg/L	Limit: 10.0

NITRATE RESULT: SAFE AT TIME OF SAMPLING.